

CITY OF AUSTIN STANDARD PRODUCTS LIST

for

FLANGED DUCTILE IRON PIPE AWWA C115

USING DEPARTMENT: Austin Water PREPARED BY: Robert Lamb. P.E. ISSUED: 04/01/03

REVISED BY: Jeff Kyle, P.E. **REVISED:** 07/01/18

DESCRIPTION: Water Pipe, Ductile Iron, Flanged, meeting AWWA C115, cement-mortar lined with

asphalt seal coat, and asphalt coated, except when specified otherwise. Machined flange

faces shall have a rust-preventative coating. Not for use in gravity wastewater applications. Approval is for flanged pipe supplied from the listed physical locations.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/01/03	BLUE PATRIOT FAB (formerly Foundry Services, Inc.) 4309 North 26 th Street Omaha, NE 68111	See notes below	R. Lamb
04/01/03	U.S. PIPE FABRICATION (formerly Custom Fab–San Antonio) 7030 Old Pearsall Rd. San Antonio, TX 78252	See notes below	R. Lamb
04/01/03	U.S. PIPE FABRICATION (formerly U.S. Pipe & Foundry Co.) 2023 St. Louis Ave. Bessemer, AL 35020	See notes below	R. Lamb
04/01/03	METRO-TEX FABRICATORS, INC. 5107 Brookglen Drive Houston, TX 77017	See notes below	R. Lamb
04/01/17	K&K SUPPLY / CUSTOM PIPE AND COUPLING 12641 FM 3083 Conroe, TX 77302	See notes below	J. Kyle

NOTES:

- 1. Acceptable sizes are 4", 6", 8", 12", 16", 20", 24", 30", and multiples of 6" in larger sizes.
- 2. D.I. Pipe by U.S. manufacturer.
- 3. Certification required for testing of each joint to 300 psi minimum.
- 4. For pipe larger than 24" diameter, manufacturer must provide one of the following with project submittal: a) evidence of current ISO registration, b) evidence of current Austin Water approved quality control program, or c) name and qualifications of independent, third party firm that will test and inspect pipe produced for City of Austin, as per Standard Specification Item 510.

LATEST REVISIONS:

- 1. Removed Fast Fabricators
- 2. Changed Foundry Services to Blue Patriot Fab
- 3. Changed Custom Fab-San Antonio to U.S. Pipe Fabrication
- 4. Changed U.S. Pipe & Foundry Co. to U.S. Pipe Fabrication